

# Compliance Statement

No. 2022-001

## Data communication cords, Category 6A

### Company

KRUGEL EXIM spol. s r.o.  
Rybnicna 38/H  
831 06 Bratislava  
Slovak Republic

### Product description

Screened Category 6A RJ45 cords (equipment, patch, and work area) characterised up to 500 MHz

### Product identification

KELine 10Giga patch cables STP Cat.6A, LS0H  
Part number: KEL-C6A-P-xxx (xxx: denotes length in dm)

### Generic cabling and cabling components standard - Category 6A balanced cord requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 61935-2:2010 (Ed. 3.0) (transmission requirements)

### Technical report

12134853-01, DANAK-19/22401

### EC Cabling product ID


5008

### CS valid until

1 March 2023

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 4 January 2022



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

