



Compliance Statement

Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

R&M Freenet, Types R35257 and R303013
Category 7, Individual Foil and Overall Braid Screened
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

Reichle & De-Massari AG
Binzstrasse 32
CHE-8622 Wetzikon, Switzerland

Compliance Statement No. 1105800

This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, the Category 6_A requirements of ANSI/TIA Generic Cabling Standard 568.2-D:2018, edition 2.1 of IEC Cable Standard 61156-5:2012 and the requirements of CENELEC Cable Standard EN 50288-4-1:2013. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 8th May 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 8th May 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager